

TRAILS END WATER DISTRICT
12/28/2020 ZOOM Working Session 4:30 P.M.
MINUTES

CALL TO ORDER: The working session came to order at 4:39 pm

ATTENDANCE: Deb Watson, Joe Morris, Sarah Carlson, Commissioners, via ZOOM

DISCUSSION TOPICS:

Ms. Watson reported that she still hasn't heard anything on the generator parts. She thinks that Cummins is probably not doing anything during the holidays.

Mr. Morris and Nick from Top Dog took the top off source three and ran the pump unrestricted. We now have confirmation of a working check valve in the top of source three.

Mr. Morris called American Leak Detector. We have 103,000 cubic feet of lost water again this month. They will come out to help us locate the leak.

We also got a call from a customer who reported that their house is shifting. The movement disconnected pipes from the meter. They used 1000 cubic feet overnight. It has now been fixed. The customer will be billed for time and parts.

There is a jerry-rigged box that is going to be replaced tomorrow. If the unauthorized hook-up is located, the old box can be installed there.

Mr. Morris explored the shed break-in. Apparently, somebody drilled into the lock to get in. He is going to put in a stronger system. He has also replaced the timer on the heater.

Agenda for January 12, 2021 meeting was set.

ADJOURNMENT:

The meeting adjourned at 5:03 pm

Submitted by Sarah Carlson

APPROVED:

Sarah Carlson 1-12-21
Sarah Carlson Date
Commissioner, Secretary

Deb Watson Date
Commissioner, President

Joe Morris 1-12-21
Joe Morris Date
Commissioner, Treasurer